Central Valley Water Reclamation Facility

January 9, 2009

ADDENDUM NO. 2
to the
Project Manual (Bidding Requirements, Contract Forms, Conditions of the Contract, Design Specifications and Design Drawings) for Construction of

Construction Contract CC5D UV Disinfection Project

INSTRUCTIONS: BIDDERS SHALL INCORPORATE THE CONTENTS OF THIS ADDENDUM AND ITS ATTACHMENTS INTO THE BID AND ACKNOWLEDGE RECEIPT THEREOF AND ACCEPTANCE OF ALL CONDITIONS CONTAINED HEREIN BY ENTERING THE ADDENDUM NUMBER AND DATE IN THE SPACE PROVIDED ON THE BID FORM, PAGE 00300-1 AND AGREEMENT, PAGE 00510-1.

CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS

SECTION 00450 – SCHEDULE OF MANUFACTURERS AND SUPPLIERS MAJOR EQUIPMENT AND MATERIAL ITEMS

Item description Number 7, Revise back to the single supplier (Cutler Hammer) listed in the original specification. The statement from Addendum No. 1 adding Siemens as supplier b shall be removed.

SECTION 16050 – MODIFICATIONS AND REMOVAL OF EXISTING ELECTRICAL INSTALLATION

Section 1.02 B "Modifications to Existing 480 V Switchgear 21", Revise back to the single supplier (Cutler Hammer) listed in the original specification. The second and third sentences of the first paragraph that were modified in Addendum No. 1 adding Siemens shall be modified to eliminate Siemens and shall read: *"This work shall include the replacement of both SWGR 21A and SWGR 21B. These existing end vertical sections are Siemens switchgear sections and shall be replaced with new Eaton Cutler Hammer Magnum DS draw out switchgear sections.*

Section 1.02 B "Modifications to Existing 480 V Switchgear 21", Change the sixth sentence of the first paragraph to read: *"It is understood that this bussing may require that the top circuit breaker compartments in each of the new vertical sections be rendered non-useable."*

Section 1.02 B "Modifications to Existing 480 V Switchgear 21", Add the following after the sixth sentence of the first paragraph: *"All remaining sections shall be made 'breaker-ready".*

DRAWINGS

Drawing S96, Detail G. Change note on drip edge flashing to: "*Min. 24 GA or thicker Type 304 SS…"*

Drawing E23202, General Note 1. Revise the note back to the note on the original drawing. The note that was modified in Addendum No. 1 allowing modification by Siemens shall be changed to eliminate Siemens and shall read: *Refer to Section 16050 for complete requirements on replacing with new Cutler Hammer switchgear sections.*

Drawing E23202, Key Note 1. Revise the note back to the note on the original drawing. The note that was modified in Addendum No. 1 allowing modification by Siemens shall be changed to eliminate Siemens and shall read: *Provide new Cutler Hammer Breakers in new Cutler Hammer switchgear section, Refer to section 16050.*

THIS ADDENDUM IS HEREBY ATTACHED TO AND MADE A PART OF THE CONTRACT DOCUMENTS. THE BIDDER DECLARES THAT IT HAS READ AND UNDERSTANDS THE CONTENTS OF THIS ADDENDUM, AND THAT ITS BID TO PERFORM THE WORK UNDER THE CONTRACT IS MADE IN CONSIDERATION OF THE ORIGINAL CONTRACT DOCUMENTS AS AMENDED BY THIS ADDENDUM AND OTHER PREVIOUSLY ISSUED ADDENDA. BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORMS DESCRIBED ABOVE. ALL OTHER PROVISIONS OF THE CONTRACT SHALL REMAIN AS GIVEN IN THE ORIGINALLY PUBLISHED DOCUMENTS.

CENTRAL VALLEY WATER RECLAMATION FACILITY

Reed Fisher

General Manager